

**HFPO-DA Results for Public and Private Water Supplies in
Vicinity of Chemours Washington Works Facility – February 2018**

	System Type	System ID	Collection Date	HFPO-DA (µg/l) or ppb*		Date of Last Carbon Changeout
				Before Treatment	After Treatment	
private		West Virginia #1	2/19/18	<0.010	<0.010	August 2011, (78 months)
private		West Virginia #2	2/19/18	0.028	<0.010	September 2016, (17 months)
private		West Virginia #3	2/19/18	0.044	<0.010	August 2013, (54 months)
private		West Virginia #4	2/22/18	<0.010	<0.010	April 2017, (10 months)
private		West Virginia #5	2/23/18	<0.010	<0.010	February 2017, (12 months)
private		Ohio #1	2/15/18	0.052	<0.010	January 2012, (73 months)
private		Ohio #2	2/16/18	0.052	<0.010	October 2012, (64 months)
private		Ohio #3	2/16/18	0.036	<0.010	April 2012, (70 months)
private		Ohio #4	2/16/18	0.016	<0.010	June 2016, (20 months)
private		Ohio #5	2/16/18	0.034	<0.010	August 2013, (54 months)
public		Chemours Washington Works (WV)	2/19/18	0.081	<0.010	February 2018, (< 1 month)
public		Lubeck Public Service District (WV)	2/12/18	<0.010	<0.010	December 2017, (2 months)
public		Belpre Public Works (OH)	2/14/18	<0.010	<0.010	November 2017, (3 months)
public		Little Hocking Water Association (OH)	2/19/18	0.032	<0.010	December 2017, (2 months)

*1.0 part per billion (ppb) = 1,000 parts per trillion (ppt)